

INSTALLATION INSTRUCTIONS

ARCTIC IP66 PICTO EXIT

PLEASE READ THESE INSTALLATION INSTRUCTIONS CAREFULLY BEFORE INSTALLING OR MAINTAINING THIS EQUIPMENT. THE PRODUCT IS DESIGNED FOR INSTALLATION AND MAINTENANCE IN ACCORDANCE WITH RELEVANT AUSTRALIAN STANDARDS (AS/NZ3000), THESE INSTRUCTIONS AND LOCAL REGULATIONS (WHERE APPLICABLE), BY AN AUTHORISED AND LICENCED ELECTRICIAN.

THE INSTALLATION INSTRUCTIONS WERE CORRECT AT THE TIME OF PRINT. TO REFLECT CHANGES IN TECHNOLOGY AND AUSTRALIAN STANDARDS; GERARD LIGHTING RESERVES THE RIGHT TO AMEND THE INSTRUCTIONS WITHOUT NOTICE. UPDATED GUIDELINES CAN BE FOUND ON www.gerardlighting.com.au.

IMPORTANT - THE PRODUCT MUST BE MAINTAINED AND OPERATED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS, FAILURE TO DO SO MAY DAMAGE THE PRODUCT AND SERVICES. IT IS STRONGLY RECOMMENDED THAT THIS IMPORTANT NOTE BE COMMUNICATED TO THE OWNER AND OR OPERATOR OF THE INSTALLATION AT THE TIME OF SITE COMMISSIONING.

FOR THE LATEST PRODUCT MAINTENANCE GUIDES PLEASE GO TO www.gerardlighting.com.au.

GERARD LIGHTING IS NOT RESPONSIBLE FOR ANY PRODUCT NOT MAINTAINED IN ACCORDANCE WITH THE RECOMMENDED PROCEDURES.

FOR RECOMMENDED LAMP MAINTENANCE GUIDES, PLEASE REFER TO THE LAMP INSTALLATION GUIDELINES SUPPLIED WITH THE LAMP PRODUCT OR THE NOMINATED LAMP MANUFACTURER'S WEBSITE.

1. PRODUCT SPECIFICATION:

| | |
|--|-------------------|
| Type of Protection | Class 1 Luminaire |
| IP Rating | IP66 |
| Nominal Voltage | 240V |
| Circuit wattage | 4.2 |
| Line current | 0.2A |
| Power factor | 0.4 |
| Nominal Freq. (Hz) | 50 Hz |
| Rated Maximum Ambient Temperature | 40°C |
| Suitable for direct mounting on flammable surfaces | NO |

2. APPROVALS:

The RCM marking of this product applies to AS/NZS CISPR15:2006 "Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment". This product is designed to conform to AS/NZS60598 "Luminaires, general requirements and tests".



3. STORAGE: Luminaires are to be stored in cool and dry conditions.

4. APPLICATION:

The installation application and orientation of the product is designed in accordance with the nominated product IP rating, class designation and these installation instructions. Installation environments outside these conditions is not recommended.

5.0 INSTALLATION:

Installation of the product is to be completed by an authorized and licenced electrician, in accordance with these instructions, relevant Australia standards and local regulations (where applicable).

For electronic control equipment (when supplied) DO NOT MEGGER between A and N. All cable terminations must be installed in accordance with the designated IP rating of the product.

6 LAMPS:

The product is designed with the supplied lamp/s and it is strongly recommended that any lamp changes be made in accordance with the type, colour and brand supplied. Gerard Lighting is not responsible for the product performance of alternative lamp/s used.

7 MAINTENANCE

The supply must be isolated before opening or accessing the luminaire.

Product maintenance is **IMPORTANT** and is critical to the products designed performance.


The product is to be maintained in accordance with the manufacturer's instructions. For the latest product maintenance guides please go to www.gerardlighting.com.au. Gerard Lighting is not responsible for any product not maintained in accordance with the recommended procedure or intervals.

For recommended LAMP maintenance guides, please refer to the lamp installation guidelines supplied with the lamp product or the nominated lamp manufacturer's website.

For products supplied with glass visors or covers, do not operate the product with a damaged visor or cover; it is recommended the product be turned off, area surrounding the product vacated and the damaged glass replaced by a professional installer immediately.




Ceiling/Cantilever bracket assembly




- 2 x 1/4 - 20UNC x 1" + Washers
- 4 x Phillips head screws for canopy
- 4 x Hex screws for canopy (use in vandal proof application)

Diffuser assembly




- 1 x Tube of clear silicone
- 8 x Phillips head screws for diffuser
- 8 x Hex screws for diffuser (use in vandal proof application)
- 16 x "O" ring



Place pictograph on to diffuser and apply clear silicone to each corner

Install "O" ring on both sides of screws


Double side Exit configuration




Remove back plate and replace (4) screws with (4) supplied nuts and screws

Double side reflector and screw fixings

Ceiling Mount



Wall Mount



Cantilever mount

